

Cape Elizabeth High School

Boiler replacement cost analysis

20-Jan-11

Engineering and Design Fees
Asbestos Abatement
Boiler plant
Sub-total

\$	21,000
\$	35,000
\$	268,000
\$	324,000

Required
Base Project *

Solar domestic water heating
Sub-total

\$	25,500
\$	349,500

Alternate

New pool heater

\$ 29,000 Town Project

* The total cost including engineering and abatement \$324,000 but requires Richards Pool heating to be shut down for two and half (2 1/2) months

** This option would not require the shut down of Richards Pool