



TOWN OF CAPE ELIZABETH
PUBLIC WORKS DEPARTMENT

10 COOPER DRIVE
CAPE ELIZABETH, MAINE 04107

ROBERT C. MALLEY
PUBLIC WORKS DIRECTOR
TEL. 799-4151
FAX 799-4426
E-MAIL: robert.malley@capeelizabeth.org

October 10, 2012

Mr. John D. Mitchell, R.L.A.
Mitchell & Associates
70 Center Street
Portland, Maine 04101

Re: Sanitary Sewer Capacity – C's Gourmet Market, Cape Elizabeth


Dear John,

Thank you for providing a letter from your office dated October 9, 2012, seeking confirmation of the Town's sanitary sewer capacity for the proposed C's Gourmet Market, to be located in Cape Elizabeth. You have estimated that the average daily wastewater flows generated from the proposed use will be approximately 431 gallons per day (gpd).

After reviewing the average daily flows currently being received by Southern Cape Elizabeth Sewer Treatment Plant, it is apparent that there is adequate capacity in the sanitary infrastructure to allow for the estimated flows that is expected to be generated by the business once it is operational.

If you have any further questions, please feel free to give me a call.

Sincerely;



Robert C. Malley
Director of Public Works

Cc: Maureen O'Meara, Town Planner