



## CAPE ELIZABETH FIRE DEPARTMENT

2 Jordan Way  
Cape Elizabeth, Maine 04107

PETER GLEESON  
Fire Chief

Tel. 207-799-6409  
Fax: 207-767-0681  
E-mail: [peter.gleeson@capeelizabeth.org](mailto:peter.gleeson@capeelizabeth.org)

Maureen, in reviewing the Strout Tower Consolidation Project I would make two recommendations. The first is that the entire length of the driveway be 14 feet wide and adequately constructed to support the weight of our apparatus. Second I would like to see an agreement that the turnaround be sized large enough to accommodate the turning radius of our apparatus and would be kept plowed in the winter.

  
Peter Gleeson