



Google

Maureen O'Meara <maureen.omeara@capeelizabeth.org>

8 Aster Lane

1 message

Peter Gleeson <peter.gleeson@capeelizabeth.org>
To: Maureen O'Meara <maureen.omeara@capeelizabeth.org>

Mon, Apr 9, 2018 at 3:42 PM

After reviewing the proposed plans for 8 Aster Lane I have the following comments.

- 1) If the current chain is removed the fire department will have adequate access to all properties on Aster Lane and South Street.
- 2) If the proposed chain is installed a turnaround would have to be installed prior to the chain as required by ordnance.
- 3) I would recommend that we stay with the 22 foot road width as required of a private road.

--

Peter Gleeson
Chief of Department
Cape Elizabeth Fire Department
2 Jordan Way
Cape Elizabeth Maine 04107
Office: (207) 767-7417
Fax: (207) 767-0681

NOTICE: Please be advised that pursuant to Title 1 M.R.S.A. Section 402(3), a public record includes any written, printed or graphic matter or any mechanical or electronic data in the possession or custody of an agency or public official that has been received or prepared for use in connection with the transaction of public or governmental business and contains information relating to the transaction of said business; therefore, the public is advised that any correspondence, whether by traditional method or e-mail with town offices or town officials, with certain limited exceptions, is public record and is available for review by any interested party.