

LOCATION PERMIT

Upon the Application of Center Maine Power Company and N/A

dated Aug 12, 2010, asking for permission, in accordance with law, to construct and maintain poles, buried cables, conduits, and transformers, together with attached facilities and appurtenances

over, under, along or across certain highways and public roads in the location described in said application,

permission is hereby given to construct, reconstruct, maintain and relocate in substantially the same location,

said facilities and appurtenances in the Town of Cape Elizabeth, approximately

located as follows:

- 1. Starting Point: Corner of Mitchell Rd & Stonegate Rd
- 2. Road (State & CMP): Stonegate Rd
- 3. Direction: NW
- 4. Distance: +/- 150 feet
- 5. Number of Poles: n/a

Facilities shall consist of wood poles and appurtenances with a minimum of wire and cable not less than 18 feet over the public highway and/or buried cables or conduit and appurtenances placed a minimum depth of 36 inches under pavement and 30 inches elsewhere, all in a manner conforming to the National Electric Safety Code.

By: _____

By: _____

By: _____

By: _____

By: _____

Municipal Officers

Office of the _____

Received and Recorded in Book _____, Page _____

Attest: _____

Clerk

Notification: 300731632

Work Order: 1000352893

CENTRAL MAINE POWER COMPANY
APPLICATION FOR POLE LOCATION OR UNDERGROUND LOCATION

In the City/Town of: Cape Elizabeth, Maine

To the: City
 Town
 County of: Cumberland, Maine

- Central Maine Power hereby applies for permission to:
 - Construct and maintain poles together with attached facilities and appurtenances upon, along or across certain streets and highways in said City/Town as described below.
 - Construct and maintain buried cables, conduits, manholes and handholes, together with wire and cables, transformers, cutouts, and other equipment therein, under, along, and across certain streets and highways in said City/Town as described below.

Central Maine Power Company and N/A jointly apply for permission to construct and maintain poles together with attached facilities and appurtenances upon, along or across certain streets and highways in said City/Town as described below.

1. Starting Point: Corner of Mitchell Rd & Stonegate Rd
2. Road (State & CMP): Stonegate Rd
3. Direction: NW
4. Distance: +/- 150 feet
5. Number of Poles: n/a

- Overhead wires shall have a minimum clearance of 18 feet over the public highway and be constructed to conform with the requirements of the National Electric Safety Code.
- Buried cable facilities shall be placed at a minimum depth of 36 inches under pavement and 30 inches elsewhere and be constructed to conform with the requirements of the National Electric Safety Code.

Any person, firm, or corporation to be adversely affected by this proposed location shall file a written objection with the State Department of Transportation, City, Town or County stating the cause of said objection within fourteen (14) days after the publication of this notice or ninety (90) days after installation of facilities without publication.

Public Notice of this application has been given by publishing the text of the same Not Published

In:
On:

CENTRAL MAINE POWER COMPANY N/A

By: Jon C Deschenes Jr. Date: Aug 12, 2010 By: _____ Date: _____

