

Central Maine Power  
Town Pole Permit  
Fax Cover Sheet

Date 4/8/14

To: Town/City of Cape Elizabeth

Fax #: 799-7141

Subject: Town Pole Permit

Town/City: Cape Elizabeth

Road: Mitchell Rd

CMP Job #: 301215763

From: Pat Shore, CMP Line Clerk

Fax 621-4552

E-mail: patricia.shore@cmpco.com

Please sign attached and fax or e-mail back.

If you have any questions or concerns please call me direct  
at 1-207-490-3033.

Thank you

Form 4501

Notification: 30125763

Work Order: 1000518726

### CENTRAL MAINE POWER COMPANY APPLICATION FOR POLE LOCATION OR UNDERGROUND LOCATION

In the City/Town of: Cape Elizabeth, Maine

To the:  City  
 Town

County of: Cumberland, Maine

Central Maine Power hereby applies for permission to:

Construct and maintain poles together with attached facilities and appurtenances upon, along or across certain streets and highways in said City/Town as described below.

Construct and maintain buried cables, conduits, manholes and handholes, together with wire and cables, transformers, cutouts, and other equipment thereon, under, along, and across certain streets and highways in said City/Town as described below.

Central Maine Power Company and Northern New England Telephone Operations LLC jointly apply for permission to construct and maintain poles together with attached facilities and appurtenances upon, along or across certain streets and highways in said City/Town as described below.

1. Starting Point: Corner of Mitchell Rd and Stone Gate Rd /Meadowview Ln

2. Road (State & CMP): Mitchell Rd

3. Direction: NW

4. Distance: 25 feet

5. Number of Poles: 1

Overhead wires shall have a minimum clearance of 18 feet over the public highway and be constructed to conform with the requirements of the National Electric Safety Code.

Buried cable facilities shall be placed at a minimum depth of 36 inches under pavement and 30 inches elsewhere and be constructed to conform with the requirements of the National Electric Safety Code.

Any person, firm, or corporation to be adversely affected by this proposed location shall file a written objection with the State Department of Transportation, City, Town or County stating the cause of said objection within fourteen (14) days after the publication of this notice or ninety (90) days after installation of facilities without publication.

Public Notice of this application has been given by publishing the text of the same  Not Published

In: \_\_\_\_\_

On: \_\_\_\_\_

CENTRAL MAINE POWER COMPANY

Northern New England Telephone Operations LLC

By: Jon Deschenes

Date: Apr 4, 2014

By: Deb Murphy  
Deb Murphy

Date: 4/8/2013

Form 4503

Notification: 301215763  
Work Order: 1000518726

### LOCATION PERMIT

Upon the Application of Center Maine Power Company and Northern New England Telephone Operations LLC,  
 dated Apr 4, 2014, asking for permission, in accordance with law, to construct and  
 maintain poles, buried cables, conduits, and transformers, together with attached facilities and appurtenances  
 over, under, along or across certain highways and public roads in the location described in said application,  
 permission is hereby given to construct, reconstruct, maintain and relocate in substantially the same location,  
 said facilities and appurtenances in the City / Town of Cape Elizabeth  
 approximately located as follows:

1. Starting Point: Corner of Mitchell Rd and Stone Gate Rd /Meadowview Ln
2. Road (State & CMP): Mitchell Rd
3. Direction: NW
4. Distance: 25 feet
5. Number of Poles: 1

Facilities shall consist of wood poles and appurtenances with a minimum of wire and cable not less than 18 feet over the public highway and/or buried cables or conduit and appurtenances placed a minimum depth of 36 inches under pavement and 30 inches elsewhere, all in a manner conforming to the National Electric Safety Code.

By: \_\_\_\_\_  
 By: \_\_\_\_\_  
 By: \_\_\_\_\_  
 By: \_\_\_\_\_  
 By: \_\_\_\_\_  
 Municipal Officers

Office of the \_\_\_\_\_  
 Received and Recorded in Book \_\_\_\_\_, Page \_\_\_\_\_

Attest: \_\_\_\_\_  
 Clerk

Form 4502

Notification: 301215763

Work Order: 1000518726

Page of

# CENTRAL MAINE POWER COMPANY

SKETCH TO ACCOMPANY APPLICATION FOR POLE OR UNDERGROUND LOCATIONS

City / Town: Cape Elizabeth

Date: Apr 4, 2014

Street: Mitchell Rd

By: Jon Deschenes

Facilities to consist of wood poles and appurtenances with a minimum clearance of wire and cables not less than 21 feet over the public highway, and/or underground facilities to consist of buried cables, conduits, transformers and manholes for operation at 7200 volts to ground single phase. Construction to be suitable for future operation at a voltage not to exceed 22KV to ground single phase. Right-of-way limits indicated are based on the best field information available. Poles/ Pads are staked. For further information call: Jon Deschenes at Central Maine Power Company tel: 207.828.2886 . Pole/Pad spans shown are approximate.

